

The School District of Palm Beaches

Project Name:

SDPBC Project No.:

SECTION 23 08 00
COMMISSIONING of HVAC SYSTEMS

PART 1 GENERAL

- 1.1 The District, under separate contract, shall provide an independent Testing, Adjusting, and Balancing (TAB) Contractor to perform TAB work for the HVAC systems.
- 1.2 The TAB Contractor shall be the District's representative for all TAB activities.
- 1.3 The Mechanical Contractor shall assist the TAB Contractor in performing his work as noted in PART 3 - EXECUTION and in Section 23 05 93 - TAB of HVAC Systems.
- 1.4 COMMISSIONING
 - A. Commissioning of a system or systems specified in this section is part of the construction process.
 - B. Documentation and testing of these systems, as well as training of the Owner's operation and maintenance personnel, is required in cooperation with the Owner's Representative and the Commissioning Provider.
 - C. Project Closeout is dependent on successful completion of all commissioning procedures, documentation, and issue closure.
 - D. Refer to Section 01 77 00 - Contract Closeout, for substantial completion details.
 - E. Refer to Section 01 91 00, Commissioning, for detailed commissioning requirements.

PART 2 PRODUCTS

- 2.1 None required

PART 3 EXECUTION

- 3.1 The Mechanical Contractor shall furnish to the TAB Contractor a complete set of architect supplement instructions, addenda, approved HVAC shop drawings, equipment performance sheets, change orders, etc. as requested by the TAB Contractor.
 - A. The District shall furnish to the TAB Contractor, a complete set of mechanical plans and Division 23 specifications.
- 3.2 The Mechanical Contractor shall coordinate with the TAB Contractor to establish written schedules for pre-TAB inspections and for TAB work.
 - A. Note Substantial Completion and Final Completion milestones on the HVAC/TAB schedules.
 - B. Complete the schedule TAB work prior to Substantial Completion.
 - C. HVAC/TAB schedule shall be consistent with and shown on the project's Critical Path Management schedule.
 - D. Any change in construction schedules that affect the TAB work shall be coordinated with the TAB Contractor.
- 3.3 The Mechanical Contractor shall notify the Commissioning Provider and TAB Contractor of hydronic system commissioning so that the Commissioning Provider and/or TAB Contractor can monitor the cleaning, flushing, filling, and chemical treatment, and observe water samples being drawn and tested.
 - A. Provide chemical treatment test report to the Commissioning Provider and TAB Contractor within 10 calendar days of completed tests.
- 3.4 The TAB work shall not commence until the Commissioning Provider and TAB Contractor have received written notice from the Mechanical Contractor that all HVAC systems are 100% complete and are operational.
 - A. Phase the TAB work for large projects, on a building-by-building basis.

The School District of Palm Beaches

Project Name:

SDPBC Project No.:

- 3.5 The Mechanical Contractor shall place all HVAC systems and equipment into complete operation during each working day of TAB work.
- 3.6 The Mechanical Contractor shall provide access to HVAC systems and equipment by supplying ladders and/or scaffolding, and opening access panels and equipment room doors.
- 3.7 As discovered or at least weekly, the TAB Contractor shall provide the Mechanical Contractor TAB punch lists of non-complying HVAC work.
 - A. The Mechanical Contractor shall replace or repair non-complying work within two workdays of receipt of written punch list and shall provide written notification of repairs to the TAB Contractor.
 - B. The TAB Contractor provides one re-TAB per item within his contract with the District.
 - C. Additional TAB fees due to repeat TAB punch items are the responsibility of the Mechanical Contractor and a Change Order reducing the Contract Amount shall reflect this.
- 3.8 If the TAB Contractor is prevented from completing his work in a timely and continuous manner (according to the established HVAC/TAB schedule) due to non-operable and/or incomplete HVAC systems, all additional fees for TAB work shall be the responsibility of the Mechanical Contractor and shall be affected by Change Order reducing the Contract Amount.
- 3.9 The District shall not release the Mechanical Contractor's 10% retainage until notified, in writing, by the TAB Contractor that all HVAC systems have been successfully Tested and Balanced in accordance with Contract Documents and Section 23 05 93.
- 3.10 The Mechanical Contractor shall verify the following items to ensure proper start-up and preliminary adjustments of air distribution systems.
 - A. Verify the air grilles (supply, return, exhaust, etc.) installation and connection to the duct system.
 - B. Verify that duct systems are clean of debris.
 - C. Verify that ducts attached with flexible connectors align (longitudinal) within ± 0.25 " , have a uniform gap within ± 0.25 " , and have a nominal gap width of 2.0".
 1. Flexible duct connectors shall not leak.
 - D. Verify that filters are clean, and the filter pull strips and spacers installed.
 1. Filter module shall NOT allow leaks around the filters.
 - E. Verify that balancing dampers are operational and fully opened.
 1. For externally insulated ductwork, verify the installation of 2" high standoff brackets for the locking quadrants.
 - F. Verify that fire and/or smoke dampers are fully open.
 - G. Verify proper fan rotation.
 - H. Verify proper belt drive alignment.
 - I. Verify capacity of fan motor overload elements (1.25*FLA).
- 3.11 The Mechanical Contractor shall verify the following items to ensure proper start-up and preliminary adjustments of hydronic systems.
 - A. Verify that the hydronic systems properly flushed, filled, purged, and chemically treated.
 - B. Verify that the strainer baskets/screens are clean.
 - C. Verify that pump/motor shaft has correct alignment.
 - D. Verify proper pump rotation.
 - E. Verify that all balancing valves are fully open and equipped with adjustable memory stops.
 - F. Verify that gauge cocks, pressure gages, and thermometers properly installed at coils, pumps, chillers, heat exchangers, etc.
 1. Extensions to allow for pipe insulation are required.

The School District of Palm Beaches

Project Name:

SDPBC Project No.:

2. Gage cocks and pressure gages at pumps shall utilize pump flange taps in order for head measurements to correlate with the pump performance map.
 3. Gage cocks at chillers shall utilize evaporator and condenser manifold gage taps in order for head measurements to correlate with the manufacturer's data.
- G. Verify capacity of pump motor overload elements (1.25*FLA).
- H. Verify that all Venturis properly installed with the minimum upstream and downstream straight pipe lengths.
- 3.12 The Mechanical Contractor shall verify the following items to ensure the proper start-up and preliminary adjustments of variable air volume (VAV) systems.
- A. Verify that the inlet duct to the VAV box is straight for a minimum of three inlet duct diameters.
 1. Flexible duct at the box inlet is NOT acceptable.
 - B. Verify that the service access to the heater control panel is a minimum of 42".
 - C. Verify that the static pressure probe is located in the main supply air duct between the last and next-to-last takeoff to the VAV boxes or is located per the drawings.
 1. Mark the location of the probe and notify the TAB Contractor of same.
 - D. Verify that the actuator of the inlet guide vanes is easily accessible; if not, relocate actuator.
 - E. Verify that VAV boxes with bottom access are NOT located over light fixtures and that access panels are equipped with quarter-turn quick-release fasteners.

END OF SECTION