

SECTION 26 05 19
EQUIPMENT WIRING SYSTEMS

PART 1 GENERAL

1.1 WORK INCLUDED

- A. Electrical connections to equipment specified under other Sections or furnished by Owner.

1.2 REFERENCES

- A. FS W C-596 - Electrical Power Connector, Plug, Receptacle, and Cable Outlet
- B. NEMA WD 1 - General Requirements for Wiring Devices
- C. NEMA WD 5 - Specific Purpose Wiring Devices

PART 2 PRODUCTS

2.1 CORDS AND CAPS

- A. Straight-blade Attachment Plug: NEMA WD 1
- B. Locking-blade Attachment Plug: NEMA WD 5
- C. Attachment Plug Configuration: Match receptacle configuration at outlet provided for equipment.
- D. Cord Construction: Oil-resistant thermoset insulated Type SO multi-conductor flexible cord with identified equipment grounding conductor, suitable for extra hard usage in damp locations.
- E. Cord Size: Suitable for connected load of equipment and rating of branch circuit over current protection.

PART 3 EXECUTION

3.1 INSPECTION

- A. Verify that equipment is ready for electrical connection, wiring, and energization.

3.2 PREPARATION

- A. Review equipment submittals prior to installation and electrical rough in.
- B. Verify location, size, and type of connections.
- C. Coordinate details of equipment connections with supplier and installer.

3.3 INSTALLATION

- A. Use wire and cable with insulation listed by a nationally recognized testing lab for the installations environmental conditions.
- B. Install pre-finished cord set where connection with attachment plug is indicated or specified, or use attachment plug with suitable strain-relief clamps.
- C. Provide suitable strain-relief clamps for cord connections to outlet boxes and equipment connection boxes.
- D. Make wiring connections in control panel or in wiring compartment of prewired equipment in accordance with manufacturer's instructions.
 - 1. Provide interconnecting wiring where indicated.
- E. Install disconnect switches, controllers, control stations, and control devices such as limit switches and temperature switches as indicated.
 - 1. Connect with conduit and wiring as indicated.

END OF SECTION